



# SUBMITTAL DATA

Project: \_\_\_\_\_

Architect: \_\_\_\_\_

Engineer: \_\_\_\_\_

Contractor: \_\_\_\_\_


Date: \_\_\_\_\_

- No-Hub Pipe and Fittings**
- SV Hub & Spigot Pipe & Fittings**
- Anaco Standard Couplings**
- Husky SD 4000 Couplings**
- Husky HD 2000 Couplings**
- Best-Set™ Closet Rings**
- Ty-Seal and EZ Tite Gaskets**

**No-Hub Pipe and Fittings** of 1 1/2" to 15" diameter. Soil waste, vent lines, rain water conductors and storm drainage lines shall bear the registered insignia of the Cast Iron Soil Pipe Institute indicating that these items comply with CISPI Standard 301 or Federal Specification WW-P-401/E74, ASTM 888, as manufactured by AB&I. IAPMO File No. 3270.



**SV Hub & Spigot Pipe and Fittings** in sizes from 2" to 15". Soil waste, vent lines, rain water conductors and storm drainage lines shall bear the registered insignia of the Cast Iron Soil Pipe Institute indicating that these items comply with ASTM A-74 and HS 74. IAPMO File No. 3274.



**Standard Couplings** shall be made with clamp assemblies that comply with the Cast Iron Soil Pipe Institute Standard 310, with shields made from series 301 stainless steel, ASTM C-564, latest revision, as manufactured by Anaco. They shall bear either the Uniform Plumbing Code (UPC) or IAPMO trademarks. IAPMO listed.



**Husky SD 4000 Couplings** shall be constructed from 304 stainless steel and provide a minimum shield thickness of .015" or greater. Shield shall be 3" wide for sizes 1 1/2" through 4", and 4" wide for 5" through 10." Couplings shall have four sealing bands on 1 1/2 through 4" sizes, and six bands on 5" through 10" sizes. All bands shall require 80 in-lbs of torque. Gaskets shall comply with ASTM C-564. Couplings shall meet the requirements of Factory Mutual 1680 and ASTM 1277 standards. IAPMO listed.




**Husky HD 2000 Couplings** shall be constructed from 304 stainless steel and provide a minimum shield thickness of .010" or greater. Shield shall be 3" wide for sizes 1 1/2" through 4", and 4" wide for 5" through 10." Couplings shall have four sealing bands on 1 1/2 through 4" sizes, and six bands on 5" through 10" sizes. All bands shall require 80 in-lbs of torque. Gaskets shall comply with ASTM C-564. Shall meet the requirements of Factory Mutual 1680. IAPMO listed.



**Best-Set™ Closet Ring** is a cast iron ring manufactured by AB&I. The Best-Set features a neoprene gasket which fills the space around the pipe and the space between the pipe and the closet ring. IAPMO File No. 3209.



**Ty-Seal and EZ-Tite gaskets** in sizes from 2" to 15" shall comply with all requirements of ASTM C-564. IAPMO File No. 0391.



**Made in USA**



*AB&I strongly recommends that its No-Hub cast iron pipe and fittings be joined with shielded couplings manufactured in accordance with CISPI 310. The use of any coupling not meeting the above specifications will void the product warranty.*

7825 San Leandro Street • Oakland, CA 94621 • 800/GOT-IRON • 510/632-3467 • Fax 510/632-8035