

Replacement Aerators and Other Spout Outlets: *Baseline Water Fixture Requirement 2.2 USGPM*

0.859" Diameter Female Thread	0.937" Diameter Male Thread	Flow Rate USGPM	Water Reduction
060637A	060638A	1.5 VR Laminar	31%
060639A	060640A	1.5 VR Aerator	31%
060641A	060642A	1.5 Non VR Aerator	31%
060726A	060818A, RP31704	0.5 VR Non-Aerating	77%
	060566A	1.0 VR Non-Aerating	55%

Metering Faucets: *Baseline Water Fixture Requirement 0.25 US gallons per cycle*

<i>Delta Metering Cartridges are factory set from 9 to 16 second cycle at 50 psi.</i>	<i>Water Reduction</i>
<i>9 Second cycle will use 0.08 US gallons of water per cycle</i>	
<i>16 Second cycle will use 0.13 US gallons of water per cycle</i>	
<i>0.5 USGPN outlet is standard</i>	
Model #	
701-HDF, 2517-HDF, 86T0104, 86T1104, 87T104, 87T110, 701-COLHDF, 3514-HDF, 86T1053, 86T1153, 87T105, 87T111, 2507-HDF	

*See current price book or www.specselect.com for pricing and complete model numbers.



A MASCO COMPANY

Delta Faucet Company
55 E. 111th St., P.O. Box 40980
Indianapolis, IN 46280

Masco Canada Limited, Plumbing Group
395 Matheson Blvd. East
Mississauga, Ontario L4Z 2H2



Printed on process chlorine free,
100% recycled paper.