



# Fire Protection Products



Date: January 1, 2008  
Subject: General Certificate of Conformance  
3M Fire Protection Products

**Product Category: Wrap Products**

*Fire Barrier Duct Wrap 15A, 20A*  
*Fire Barrier Duct Wrap Collar*

*Fire Barrier Plenum Wrap 5A*  
*Fire Barrier Grease Duct Access Door*

**These Products are tested to one or more of the following standards:**

- UL 1978 Grease Duct 1 or 2 hour Shaft Enclosure (Sections 12 and 13)
- ICBO ES AC101 Grease Ducts, Flexible Enclosure Systems
- ASTM E 119 (ANSI/UL 263) Fire Tests of Building Construction and Materials Time-Temperature Curve
- ASTM E 814 (ANSI/UL 1479) Fire Tests of Through-Penetration Fire Stops
- ASTM E 84 (ANSI UL 723) Surface Burning Characteristics of Building Materials
- ASTM E 136 Test Method for Behavior of Materials in a Vertical Tube Furnace @ 750°
- ASTM C 411 Hot Surface Performance of High Temperature Thermal Insulation
- ASTM C 518 Product Aging Tests
- UL 910 Test Method for Fire and Smoke Characteristics of Cables
- UL 1887 Fire Test of Plastic Sprinkler Pipe for Visible Flame and Smoke Characteristics
- ASTM E 2336 Standard Test Methods for Fire Resistive Grease Duct Enclosure Systems

No asbestos, PCB's, or lead are used or contained in these products.

Issued by:

Quality Manager or Designee

Product Service Manager, or Designee